

TABLE OF CONTENTS

Sprinklers in Hotels and Motels

Sprinklers in hotels and motels 29-315-1

Sprinklers in Hotels and Motels**Sec. 29-315-1. Sprinklers in hotels and motels**

Each hotel or motel having six or more guest rooms and providing sleeping accommodations for more than sixteen persons for which a building permit is issued for new occupancy on or after January 1, 1987 shall have an automatic extinguishing system installed on each floor in accordance with the requirements of the Connecticut Basic Building Code and the Connecticut Fire Safety Code, as they may from time to time be amended.

(Effective February 25, 1988)